

Performance Evaluation of Refrigeration Systems Using Nanofluids: A Numerical and CFD Analysis Review

Johan Svensson¹, Mikael Andersson² & ^{3*}Oskar Karlsson

¹M.Tech Scholar, Mechanical Engineering Dept, Chalmers University of Technology, Gothenburg, Sweden

²Assistant Professor, Mechanical Engineering Dept, Chalmers University of Technology, Gothenburg, Sweden

^{3*}Lecturer, Mechanical Engineering Dept, Chalmers University of Technology, Gothenburg, Sweden

ABSTRACT

In today's world, refrigeration systems play an important role to satisfy the human desires and a continual analysis is being dispensed by several researchers so as to enhance the performance of those systems. In cooling and heating applications, thermophysical properties of matter play an excellent role. It's been determined that the performance of any system mainly depends on the thermal conductivity, viscosity, heat energy and density of gasses and liquids that are utilized in the system. Standard fluids have poor heat transfer capability and low thermal conduction that limits its performance. Thanks to this, there's continually a necessity to develop effective & economical fluids capable to agitate high heat transfer rate. Small solid additives sometimes in micrometer are sensible choice to enhance the thermal properties of fluids; however it's been found that these small solid additives cause variety of issues like particle deposit, particle impeding, and also the massive pressure drop by the system, corrosion of parts, etc.

KEYWORDS: Refrigeration, Nano-Fluids, CFD, Thermal Conductivity, Conventional fluids, Heat transfer Coefficient etc.

I. INTRODUCTION

Refrigeration is additionally made public as a result of the strategy of achieving and maintaining a temperature below that of the surroundings, the aim being too cool some Product or space to the specified temperature. One in every of the foremost very important applications of refrigeration has been the Preservation of spoilable nutrient by storing them at low temperatures. Refrigeration systems are also used extensively for providing thermal comfort to groups of people by implies that of air conditioning. The refrigeration and air conditioning sector in India contains a protracted history from the first years of last century. India is presently producing R134a, R22, R717 and hydrocarbon-based refrigeration and air conditioning units in large quantities. The Utilization of CFC refrigerants in new systems was stopped since the year 2002. The factors that Dictate the adoption of a specific refrigerant apart from its quality for the precise application are its accessibility and worth. The halogenated refrigerants like R12, R22, R134a and natural refrigerant like R717 are promptly on the market at low prices. The compound (HC) and Hydro Fluoro Carbon (HFC) mixtures (such as R404a, R407, and R410A) do not appear to be presently ready-made indigenously and therefore ought to be foreign at a stronger worth. This will be on the face of it to possess an impression on the growth in refrigeration and air conditioning sector in India and in addition the total conversion to environmentally friendly alternatives at intervals the near future.

Nanofluids

Nanofluids are a suspension of particles between 0 and 100 nm in a base fluid. They have thermophysical properties different to the base fluid due to the addition of metal or metal oxide particles to increase the coefficients of thermal conduction and convection. The main characteristic of Nanofluids is the ability to enhance heat transfer without altering the base fluid Newtonian behaviour with the addition of small concentrations of solid particles. Experimental and numeric tests have been performed in order to better understand the behaviour of these fluids and their characteristics. Studies have focused on thermal conductivity, convective heat transfer coefficient, viscosity, evaporation phenomenon, the influence of particle size and optimal concentration of particles.

Some of the advantages to using Nano-fluids proposed by Choi in are:

- High specific surface area and therefore greater heat transfer surface between particles and fluid.
- High stability of the dispersion where the Brownian motion of particles dominates.
- Reduction of the pumping power in comparison with the base liquid, to achieve an equivalent heat transfer.
- Reduced clogging particles compared to conventional suspensions, promoting miniaturization of the system.

- Adjustable properties by varying the concentration of particles. In, the authors describe the challenges faced in studying Nanofluids and its characteristics such as thermal conductivity, the Brownian motion of particles, migration of these and the variation of thermophysical properties with change in temperature.
- The long-term stability of the dispersion of nanoparticles is a technical challenge to prevent the accumulation and sedimentation of particles. The pressure drop and higher pumping power should also be considered to determine the efficiency of Nanofluids. Other challenges include an increase in viscosity with a greater concentration of particles, low specific heat compared to the base fluid, the prediction of thermal conductivity, high costs and production processes.

Nanofluids application

Heat transfer fluids are the most important part of cooling applications in many industries including transport, energy, manufacturing, and electronics. Nanofluids can be used to improve heat transfer and energy efficiency a variety of thermal system, including the important applications of refrigeration vehicles. Some applications of Nanofluids will discuss below-

Nanofluids for Lubrication Applications

Solid lubricants useful in situations where conventional lubrication is not enough liquid, such as high temperature and excessive contact pressure, their lubricating properties are due to the layer structure at the molecular level with weak bonding between the layers. Graphite and molybdenum disulfide (MoS₂) is the main material used as solid lubricants. Other useful solid lubricants include boron nitride, tungsten disulfide, polytetrafluoroethylene (PTFE), etc. to improve the tribological properties of lubricating oils, solid lubricant nanoparticles to disperse. Recent studies have shown that the lubricating oil with additional nanoparticles exhibits improved load carrying capacity, anti-wear and friction reduction property.

Nanofluids for Biomedicine Applications

Nanofluids have many applications in the biomedical industry. For example, Nanofluids are used to producing effective cooling around the surgical region and thereby enhancing the patient's chance of survival and reducing the risk of organ damage. In a contrasting application to cooling, Nanofluids could be used to produce a higher temperature around tumours to kill cancerous cells without affecting nearby healthy cells.

Nanofluids for Cooling Applications

Developments in new technologies such as highly integrated microelectronic devices, the engine power output are higher, and the reduction of cutting fluids used continuously increasing heat load, which requires the development of cooling capacity. Thus, there is a need for a new heat transfer fluids and innovative ways to achieve better cooling performance. In general, the conventional heat transfer fluid has the characteristics of poor heat transfer compared to the solid, most solids have thermal conductivities orders of magnitude greater than that of conventional heat transfer fluids.

Therefore, the liquid containing suspended solid particles are expected to exhibit a significant increase in thermal conductivity compared with conventional heat transfer fluids. In addition, normal coolant operating temperature can be increased since Nanofluids have obtained a higher boiling point, which is desirable for maintaining single phase coolant flow. The results of Nanofluids research are being applied to the cooling of an automatic transmission with variable operating speeds conducted.

Others Application

There are unending situations where an increase in the heat transfer effectiveness can be beneficial to be the quality, quantity, and cost of product or process. In many of these situations, Nanofluids are good candidates for accomplishing the enhancement in heat transfer performance. For example, Nanofluids have potential application in buildings where increases in energy efficiency could be realized without increases in energy efficiency without increased pumping power. Such an application would save energy in as heating, ventilating and air conditioning system while providing environmental benefits. In the renewable energy industry, Nanofluids could be employed to enhanced heat transfer from solar collectors to storage tanks and increase the energy density. Nanofluids coolants also have potential application in major process industries, such as materials, chemical, food and drink, oil and gas, paper and printing, and textiles.

Nano-refrigerants

Recently nanoparticles have been used to enhance the thermophysical properties of refrigerants in order to achieve greater efficiency and profitability in refrigeration and air conditioning. In the literature, studies have reported rheological and heat transfer mechanisms to different concentrations of CuO nano particles, Al₂O₃, SiO₂, diamond, CNT (carbon nanotube), TiO₂ as refrigerants R11, R113, R123, R134a and R141b. The effect of the

size of the nanoparticles on heat transfer in mixtures of refrigerant, oil, and nanoparticles is investigated experimentally with R113, VG68 oil and Cu particles with diameters of 20, 50 and 80 nm. The results show a maximum increase of 23.8 % in the heat transfer coefficient in a pool nucleate boiling with reduced diameter from 80 to 20 nm. One of the main factors in the efficiency of a refrigeration system with nano-refrigerants is the heat transfer in the phase change of the heat exchangers (evaporator and condenser). Heat transfer by flow boiling of nano-refrigerants was studied using a mixture of R113 and CuO particles. Experimental tests show a 29.7 % increase in the heat transfer coefficient due to the addition of CuO nanoparticles.

II. LITERATURE REVIEW

Coumaressin and Palaniradja (2015) have studied regarding Evaporating heat transfer that is extremely necessary within the refrigeration and air-conditioning systems. HFC 134a is that the largely wide used various refrigerants in refrigeration instrumentality like domestic refrigerators and air conditioners. Tho' the worldwide warming up the potential of HFC134a is comparatively high, it's affirmed that it's a protracted term various refrigerants in numerous countries. By the addition of nanoparticles to the refrigerant leads to enhancements within the thermophysical properties and warmth transfer characteristics of the refrigerant, thereby up the performance of the cooling system. In these experiments, the result of mistreatment CuO-R134a within the vapour compression system on the evaporating heat transfer constant was investigated by CFD heat transfer analysis mistreatment the FLUENT software system. Associate experimental equipment was built in step with the national standards of the Asian nation. The experimental studies indicate that the cooling system with nano-refrigerant works unremarkably. Heat transfer coefficients were evaluated mistreatment FLUENT for warmth flux ranged from 10 to 40 kW/m², mistreatment nano CuO concentrations ranged from 0.05 to 1 / 4 and particle size from ten to 70 nm. The results indicate that evaporator heat transfer constant will increase with the usage of nanoCuO.

Thangavel et al. (2013) studied the performance of compression cycle is assessed on paper with completely different refrigerants. In compression cooling, organic compound refrigerants like R290 and R600a are thought-about as a refrigerant by combination of those at completely different mass fractions concerning 20%+80%, 25%+75%, 50%+50% and 75%+25% severally. Varied performance measures like mechanical device discharge temperature, pressure quantitative relation, volumetrically cooling capability (VCC), volumetrically potency and mass rate of flow area unit analyzed. The results area unit compared with halogenated refrigerants like R134a, R12 for various condenser and evaporator temperatures. Halogenated compounds are having direct environmental impacts in turns of ODP and GWP. Among the organic compound refrigerants cluster, the mixture of R290 and R600a at concentration of 50 every has optimum performance in terms of upper refrigeration impact, higher heat transfer and COP.

Verma and Chaudhary (2017) have established the Ejector growth refrigeration system achieves the numerous improvements in constant of performance as compared to different system. Use of AN ejector as growth device is one amongst the choice ways that. The performance of a vapour compression system that uses AN ejector as a growth device is investigated. Ejector growth Refrigeration systems square measure analysed during this article exploitation constant pressure and constant space mix ejector as a growth device. This paper provides a comparison between constant pressure and constant space model exploitation R-1270 as a refrigerant. Within the analysis, a two-phase constant space and constant pressure ejector flow model was used. Pressure variation on the length of the ejector is obtained for constant space model. The pressure variation is found to be higher for constant space ejector model compared to constant pressure model.

Rakesh et al. (2017) have studied on the point of Improve the constant of Performance (COP), it's needed to decrease the mechanical device Work and increase the cold result. Experimental analysis on vapour compression refrigeration (VCR) system with R134A (Tetra Fluro Ethane) refrigerant was done and their results were recorded. The consequences of the most parameters of performance analysis square measure mass flow of refrigerant, suction pressure of mechanical device, delivery pressure of mechanical device, temperature of evaporator and condenser. The results from vapour compression refrigerant plant was taken wherever the variables like suction pressure of mechanical device, delivery pressure of mechanical device, temperature of evaporator and condenser were noted and constant of performance (COP) was calculated. The results obtained are going to be valid through CFD simulation. Additional diffuser has been introduced in between mechanical device and condenser in order that power input to the mechanical device has been reduced there by enhancing COP. The improvement is completed through CFD simulation; Modelling and meshing is completed in ICEMCFD, analysis in CFX and post leads to CFD POST.

III. OBJECTIVES OF THE PRESENT STUDY

Many investigations have been done to deal with the problem of global warming and ozone layer depletion due to the use of alternative refrigerants in the refrigeration system. Therefore it is felt that detailed investigations on the possibility of adding a new alternative refrigerant and Nano additives to the refrigerant and the comparison between the different nano fluids will be analyzed using CFD simulation. Our main objective of the present study is to investigate the heat transfer characteristics of the multiphase refrigeration system; the compound (R134a + R152a) is taking as a major refrigerant and three nano fluids are Al_2O_3 , CuO and ZnO. The most widely used commercial refrigerant R134a and proven alternate R152A were mixed and new hybrid refrigerant will be prepared and the properties of heat transfer will be examined by the concentration of different quantities. The most commonly used commercial refrigerant R134a and the proven alternative R152a were blended and the new hybrid refrigerant was prepared and the heat transfer characteristics will be investigated with different volume concentration.

1. Nano additives such as ZnO, CuO and Al_2O_3 were blended with R152a refrigerant and their corresponding performance on the same system was investigated.
2. Nano additives of Al_2O_3 , CuO and ZnO of 0.05%v, 0.1 % v and 0.15%v concentration with particle size of 40-50 nm and 150 nm of R152a was charged investigated by CFD Simulation. Nano particles with refrigerant mixture were used in HFC R152a refrigeration system. The system performance with nano particles was then investigated according to the heat transfer characteristics.

IV. PROBLEM DEFINITION

The Global Warming Potential (GWP) of currently used R134a is high as 1300. The Ozone Depleting Potential (ODP) of R134a is also relatively high. The Montreal and Kyoto Protocol of United Nations suggests minimizing of Hydro Fluoro carbons (HFCs) to use as refrigerants. Researches show HFC 134a not much miscible with lubricant oil in the compressor. European countries have already banned R134a. Blending of R134a with other HFC is a problem. R-22 and R134a will be phased out due to environmental issues. To overcome the above problem, refrigerant R152a is proposed in the present study because R152a has Zero Ozone Depleting Potential and a very less value of 120 as Global Warming Potential (GWP) when compared to other refrigerants. The atmospheric life span for R152a is 1.4 years. Pure substance R152a offers excellent thermodynamic properties non toxic and compatibility with the conventional oil in compressor. R152a has been already approved for use in automobile applications as an alternative to R134a by US Environmental Protection Agency. The refrigerant then enters the condenser as superheated vapour at state 2 and leaves as saturated liquid at state 3 as a result of heat rejection to the surroundings. The temperature of the refrigerant at this state is still above the temperature of the surroundings.

The saturated liquid refrigerant at state 3 is throttled to the evaporator pressure by passing it through an expansion valve or capillary tube. The temperature of the refrigerant drops below the temperature of the refrigerated space during the process. The refrigerant enters the evaporator at state 4 as a low quality saturated mixture, and it evaporates by absorbing heat from the refrigerated space. The refrigerant leaves the evaporator as saturated vapour and re-enters the compressor, completing the cycle.

V. PROPOSED METHOD

- Comparison of cases
- Changing the parameter in the processes of periodic flow
- 3D CAD modeling in Ansys Fluent
- Preprocessing of the CAD geometry
- Numerical modeling or discretization is to be done in Ansys (Fluent14.5)
- Defining the cell zone for fluid
- Defining the boundary condition

VI. PROPOSED RESULTS

- Temperature distribution
- Pressure distribution
- Velocity profiles
- Temperature distribution at different position
- Heat Transfer Rate
- Mass fraction of emissions

VII. REFERENCES

- [1] P. Thangavel, Dr. P. Somasundaram, T. Sivakumar, C. Selva Kumar, G. Vetriselvan “Simulation Analysis of Compression Refrigeration Cycle with Different Refrigerants” ISSN: 2277-3754 ISO 9001:2008 Certified International Journal of Engineering and Innovative Technology (IJEIT) Volume 2, Issue 10, April 2013.
- [2] Ravi Verma, Sharad Chaudhary “Analysis of Constant Pressure and Constant Area Mixing Ejector Expansion Refrigeration System using R-1270 as Refrigerant” International Research Journal of Engineering and Technology (IRJET) e-ISSN: 2395 -0056 Volume: 04 Issue: 06 | June -2017 www.irjet.net p-ISSN: 2395-0072.
- [3] Rakesh R., Manjunath H. N., Krupa R., Sushanth H. Gowda, Kiran Aithal S. “A Study on Enhancing COP in VCR by Providing Diffuser in between Condenser and Compressor” Energy and Power 2017, 7(5): 142-148 DOI: 10.5923/j.ep.20170705.04
- [4] Kornhauser AA. The use of an ejector as a refrigerant expander. Proceedings of the 1990 USNC/IIR-Purdue Refrigeration Conference, West Lafayette, IN, U.S.A., 1990; 10–19.
- [5] Li Daqing, Groll E.A. Transcritical CO₂ refrigeration cycle with ejector- expansion device. International Journal of Refrigeration 28 (2005); 766–773.
- [6] J.Sarkar, “Performance characteristics of natural refrigerants based ejector expansion refrigeration cycles,” Proceedings of the IMechE, Part A: Journal of Power and Energy 2009,223, pp. 543–50.
- [7] Sarkar J. Geometric parameter optimization of ejector-expansion refrigeration cycle with natural refrigerants. International Journal of Energy Research 2010; 34:84-94.
- [8] J.Sarkar. Renewable and Sustainable Energy Reviews 16, Issue 5 October 2012
- [9] Raman S, Chaudhary S. Methods to Improve the Performance of VCR Cycles using R-1270 as Refrigerant ; International Journal of Scientific and Research Publications, Volume 3, Issue 5, July 2015.
- [10] Mohanraj.M, Jayaraj.S, Muraleedharan.C and Chandrasekar.P (2009) “Experimental investigation of R290/R600a mixture as an alternative to R134a in a domestic refrigerator”, International Journal of Thermal Sciences Vol.48, pp.1036–1042.
- [11] Maclaine-Cross.I.L (1997), “Why hydrocarbons save energy”, AIRAH Journal, June 1997, Vol.51, pp.33-37.
- [12] Fatouh. M and El Kafafy.M (2006), “Assessment of propane/commercial isobutene mixtures as possible alternatives to R134a in domestic refrigerators”, Energy conversion and management, Vol.47, pp.2644-2658.